

**PALOMAR ENERGY PROJECT (01-AFC-24)
CEC STAFF DATA REQUEST NUMBER 67**

Technical Area: Transmission System Engineering

Response Date: April 8, 2002

REQUEST:

Please include the Inland Empire Energy Center for all base cases for the above mentioned scenarios including peak and off peak seasons, with and without the Rainbow Valley Interconnect transmission line.

RESPONSE:

Inland Empire is located outside of the SDG&E Simultaneous Import Limit (SIL) interchange points. Therefore, generation from Inland Empire is reflected in the import levels studied in the DFS (e.g., 3,600 MW import).